

ISO New England Operating Procedure No. 4 - Action During A Capacity Deficiency

Effective Date: November 29, 2023

Review By Date: November 29, 2024

REFERENCES:

1. NERC Reliability Standard EOP-011 - Emergency Preparedness and Operations
2. NERC Reliability Standard COM-002 - Operating Personnel Communications Protocols
3. NPCC Directory #2 Emergency Operations
4. NPCC Directory #5 Reserve
5. ISO New England Inc. Transmission, Markets and Services Tariff Section III,

*This document is controlled when viewed on the ISO New England Internet web site. When downloaded and printed, this document becomes **UNCONTROLLED**, and users should check the Internet web site to ensure that they have the latest version.*

ACTION 4 (An ISO responsibility)

Implement a Power Watch.

II. CANCELLATION OF ACTIONS

When the system conditions have sufficiently improved, ISO shall cancel the Actions instituted in this OP Section I. Depending on system conditions, the order of Action cancellation may be different than the order of Action initiation.

III. IMPLEMENTATION BY LCCs

Any of the Actions provided in this OP may be implemented by an LCC to deal with local conditions within that LCC

VI. PUBLIC NOTIFICATIONS

Notifications associated with forecast or actual implementation of OP-4 shall be conducted in accordance with CROP.10002 Implement Capacity Remedial Actions. Power Advisories shall be issued by ISO via its external website. These Power Advisories shall be triggered by the implementation of certain Actions of OP-4 as described below. These notifications are considered public information.

Power Caution

A Power Caution is triggered by the initial implementation of OP-4 Action 1. A Power Caution is defined as a notification that electric reserves can **no** longer be maintained using normal measures. Although full reserves are **not** being maintained, utility personnel will begin to take steps to manage these reserves.

Power Watch

A Power Watch is triggered by the implementation of OP-4 Action 4. A Power Watch is defined as a notification that further steps to manage capacity could

Rev. No.	Date	Reason
Rev 18	05/07/19	Annual review completed by procedure owner; Appendices Section and last paragraph of Part I, administrative changes to update the load in Appendix A title, in last paragraph replaced "will" with "may"; Part I, Action 1, deleted the parentheses around Settlement Only; Part I, Action 7, 1 st