6. Performance Measures 31

7. References 31

8. Revision History 31

9. Attachments 32

- A CD-SPD startup
- A request for a cure audit from a Lead MP/DE

The following are outputs of the processes from performance of a task(s) in this SOP:

- CLAIM10 and CLAIM30 audit results, compiled daily and weekly
- Failure to Activate (FTA) results
- CLAIM10 and CLAIM30 daily and weekly reports
- Completed flagging in the Gateway Data Modification Application (GDMA) for historical data modifications

The following applications/systems/tools are used in task(s) performance in this SOP:

- ISO Outage Scheduling software
- R Studio
- Plant Information (PI) database
- Capping User Interface (UI0.41.6 (a)-55.( )]164 /P <</MCID 52 58 >>BDC -16 -2 Td( )TjEMC /

5. Instructions

5.1 Review Failure to Activate (FTA)

An FTA Forward Reserve determination is conducted for a Resource when the following conditions exist:

- The Resource is dispatched by an approved CD-SPD between peak hours 0700-2300, Monday through Friday, excluding the North American Electric Reliability Corporation (NERC) holidays (on-peak).
- The Resource was assigned a Forward Reserve Obligation during the Hour Ending (HE) that was CD-SPD approved.
- In addition to the previous conditions, a Simultaneous Activation of Ten Minute Reserve (SAR)/ Mutual Reserve Assistance (MRA) Event Report email may be received indicating that there was a contingency.

5.1.1 Access CD-SPD Query Results

1. The Analyst shall PERFORM the following actions to access and OBTAIN the CD-SPD Query results for an FTA Review:

   A. OPEN the "ASM PH II RPM" email inbox.

   B. OPEN.133 Td(B.)Tj/TT2 1 Tf0.933 0 Td( )Tj/TT5 1e.80.4 0 Td[(S)-10. 0 Td[(R)-32.7 3

I. DESELECT the “FailToActivate30MinFlag” checkbox

J. In order for the SMS application to accept the 10-minute entries, ENTER zero for both the “ContingencyTarget30MinMw” and “ContingencyAct30MinMw”.

K. ENTER the 10 Minute Contingency Target MW value into the “ContingencyTarget10MinMw” field.

L. ENTER the 10 Minute Contingency Activation MW value into the “ContingencyAct10MinMw” field.

M. CLICK on the “Save” button.

N. VERIFY errors are saved in the record.

O. If an error is discovered after saving, SELECT the Resource in question and:

- MODIFY or DELETE the record as needed.

n. If any audits performed have a result of "Invalid Test", further action is required.

o. If any audits performed have a result of "Failed", ENTER the required information in the "Failure to Activate Template.doc" located at:

\\iso-ne.com\shares\performance_auditing\Performance Monitoring\Audit Resource Parameters\Claim 10 30\FTA Results\

p. SAVE this document as "Failure to Activate MMDDYYYY.docx" in the proper YYYY FTA Automation Folder in the correct monthly subfolder if previously created above.

5.1.5 *Perform DRR TMOR FTA Review*

1. Upon receipt of email with subject line of "Claim 10/30 TMOR FTA Data File for [DATE]" proceed with the following steps:

A. To perform the FTA Review, the Analyst shall PERFORM the following actions:

(1) OPEN and EXECUTE R Studio Script "FTA DRR TMOR Blend Script.R"" folder, located at:

\\iso-ne.com\shares\performance_auditing\Performance Monitoring\Audit Resource Parameters\Claim 10 30\FTA Results\

(2) FOLLOW the pro7 (R)-10vA8c Td( )c 0 Tw 11.4 9--------(u)56.3 (r-22 (o pe)-55.7 ----(

\ \PPPs

(4) To retrieve the blend results from R, REFRESH the DRR - FTA Automation Workbook, sheet "FRM-TMOR Results"

(5) SELECT the 'TMOR Audit' Sheet

(6) To evaluate a Resource automatically, SELECT the "Asset Short Name" from the drop down list.

(7) CLICK on the "Save" button.

(8) REPEAT previous steps for all on-line Resources.

(9) If any Resource has a result of "Invalid Test", further action is required.

(10) If any Resource has a result of "Pass", further action is required.

(11) If any Resource has a result of "Failed", ENTER the required information in the "Failure to Activate Template.doc" located at:

\\iso-ne.com\shares\performance_auditing\Performance Monitoring\Audit Resource Parameters\Claim 10 30\FTA Results\

(12) SAVE this document in the proper YYYY FTA Automation Folder in the correct monthly subfolder.

(13) If any audits performed have a result of "Invalid Test", further action is required.

(14) If any audits performed have a result of "Failed", ENTER the required information in the "Failure to Activate Template.doc" located at:

\\iso-ne.com\shares\performance_auditing\Performance Monitoring\Audit Resource Parameters\Claim 10 30\FTA Results\

(15) SAVE this document as "Failure to Activate TMOR - MMDDYYYY.docx" in the proper YYYY FTA Automation Folder in the correct monthly subfolder if not previously created above.

5.1.6 Enter TMOR FTA Failures into SMS

1. When an5.7 (i)45 (l)45 nF (x")-55.7 ( )p 152.8 164 Tm(1.)TjQBT/T7 (nt)-21-44 R FTA Faiaiaie FTMORx" Tx"bo33 0 T3.6 396 65.6 reW nBT/TT4 1E (t)-21.7 (e)E[(M)-10.7 (O

Q. ATTACH the "Failure to Activate MMDDYYYY.docx" to an email and SEND the email to the Hourly Markets Settlement department using "MktOps Stlmnt HourlyMkts" distribution list

- VERIFY the new Cap values are appropriate based on current Cap values and any starts processed over the last week.
- UPLOAD the caps the the maketsheUpCID 15 >>BDC /TT4 1 Tf1597.4 (11)

A. ENTER the new Cap value in the “New Value” field.

B. ENTER a reason.

C. CLICK on the “Update” button.

D. CLICK on the “Close” button to close the window.

E. When all changes for a particular date have been entered, CLICK on the “Finalize” button.

5.5 ISO-Initiated Claim 10/30 Audits

At the beginning of each month, this process is used to determine the recommended Resources to audit. The criteria used to recommend Resources for auditing may be modified with Control Room concurrence and should be shared unless otherwise directed by the Director, Operations Support Services.

Because ISO-Initiated Claimed Capability Audits are Lead MP/DE-requested, they are considered audits for the purposes of PF target value calculation per the Tariff, MR1 III 9.5.3.3(b)(i) CLAIM10 and CLAIM30 Performance Factors. ISO-Initiated Audits use the target value calculation from the Tariff, MR1 III Section 9.5.3.3(a) CLAIM10 and CLAIM30 Performance Factors.

The R Script used to generate the audit list also generates a separate file, which contains a list of Resources selected for audit, but could not be audited due to CROW outages.

5.5.1 Scheduling Generator Audits

1. At the beginning of each month, in order to determine the recommended Assets to audit, the Analyst shall PERFORM the following:

   A. OPEN "ISO Initiated Audit List Generator Script.R" from \\isofilpd1\tso\Claim 10_30 Auditing\ISO

P. SEND an email to GenerationOutageCoordinator" email address informing the outage coordinator group that an outage has been submitted.

5.5.2 Scheduling DRR Audits

1. The Analyst shall CREATE an ISO Claim 10/Claim 30 Audit Request in the Demand Response Audit and Testing Tool (DRATT) for any DRR as requested by the Control Room as follows:

   A. SELECT "DR Audit and Testing Tool" from the "SMD Applications Home Page"

   B. SELECT "Demand Response Resources" tab

   C. SEARCH for the DRR upon which the audit will be performed

   D. SELECT the box(es) beside the DRR(s) upon which the audit will be performed

   E. SELECT "Request Audit(s)" button

   F. SELECT "ISO" from "Request Source" drop-down menu

   G. SELECT "Claim 10/Claim 30" from "Audit Type" drop-down menu

   H. VERIFY "No" is selected for "Post Dispatch Audit"

   I. ENTER the target MW into "Desired Dispatch MW"

   J. SELECT "Create Audit Request"

7	02/13/18	Biennial review by procedure owner; Globally, made editorial changes to procedure to reflect business tool changes, current conditions, practices, and management expectations; Made updates to the network paths to tools;	Michael Jaeger
8	06/20/18	Biennial review by procedure owner; Globally, made editorial changes to procedure to reflect business tool changes, current conditions, practices for grammar/terminology/etc., and management expectations; Modified Section 5.4 title, added "Generator": Added new sub-Section 5.5.1 title (Scheduling Generator Audits); Added new sub-Section 5.5.2 titled Scheduling DRR Audits and steps and substeps; Added new Section 5.8 titled Manual Response Rate Auditing, steps and sub-steps;	Michael Jaeger
9	12/05/18	Biennial review by procedure owner; Modified step 5.1..1.1.B and 5.1.1.1.C deleted sub-steps and re-numbered remaining steps; Modified step 5.1.1.1.D; Step 5.1.2.1.A, modified sub-steps 5.1.2.1.A.(1), (2) and added new sub-step (3) and its sub-steps, modified sub-step 5.1.2.1.A.(4), deleted sub-step 5.1.2.1.A.(5) and added new sub-steps (5) and (6), modified sub-steps (7) and (8), deleted sub-step 10 and re-numbered remaining sub-steps, modified sub-steps (11), (12), and (13); Added new Section 5.3, sub-section, steps and sub	